

**OKLAHOMA STATE UNIVERSITY - BUILDING DESIGN STANDARDS**

PART 1 GENERAL

1.01 SUBMITTALS:

- A. Product Data: Submit manufacturer's product data and installation instructions for each material and product used.
- B. Samples: Submit two representative samples of each material specified indicating visual characteristics and finish. Include range samples if variation of finish is anticipated.
- C. Maintenance: Submit instructions for proper maintenance and cleaning.
- D. Provide an additional two boxes of each type, color, texture and pattern for future use.

1.02 QUALITY ASSURANCE:

- A. Qualifications:
  - 1. Manufacturer: Firm with not less than three years of production experience with resilient wall base manufacturing, and whose published product literature clearly indicates general compliance of products with requirements of this section.
  - 2. Installer: Firm with not less than three years of experience on projects of similar size and type to work of this section.

PART 2 PRODUCTS

2.01 MATERIALS:

- A. Resilient Wall Base: ASTM F 1861.
- B. Resilient Stair Accessories:
  - 1. Rubber Stair Treads: FS RR-T-650, Composition A.
  - 2. Vinyl Stair Treads: FS RR-T-650, Composition B.
- C. Rubber Tile: ASTM F 1344
  - 1. Class: I-A (homogeneous rubber tile, solid color).
  - 2. Class: I-B (homogeneous rubber tile, through mottled).

**OKLAHOMA STATE UNIVERSITY - BUILDING DESIGN STANDARDS**

2.02 AUXILIARY

- A. Concrete slab primer: Non-staining type.
- B. Trowelable underlayment and patching compounds: Latex modified, Portland cement-based formulation.
- C. Stair tread nose filler: two-part epoxy compound.
- D. Adhesives:
  - 1. Adhesive shall be water-resistant, mildew-resistant, non-staining, non-gassing (low VOC) type as recommended by the manufacturer for products and subfloor conditions indicated and shall be approved by the Owner. Comply with flammability requirements for installed tile.

**END OF SECTION 09651**