

**OSU EHS Department
Incident Summary**
For the Period 01/14/08 – 01/20/08

013-08	01/14/08	6:51 PM	Kelley
Incident:	Fire Alarm		
Location:	Bennett Hall West		
Details:	Smoke from cooking activated detector		
014-08	01/15/08	9:45 AM	Stephenson
Incident:	Fire Alarm		
Location:	Jones Hall		
Details:	Smoke from cooking activated detector		
015-08	01/15/08	10:52 AM	Stephenson
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. F		
Details:	Steam from shower activated detector		
016-08	01-15-08	7:36 PM	Kelley
Incident:	Fire		
Location:	McElroy Hall, west side of building		
Details:	Probably caused by hot charcoal dumped in trash can		
017-08	01/16/08	8:50 AM	Nutt
Incident:	First Aid		
Location:	Life Science East		
Details:	Patient fainted		
018-08	01/16/08	7:47 PM	Kelley
Incident:	Fire Alarm		
Location:	Peterson Apartments		
Details:	Smoke from cooking activated detector		
019-08	01/17/08	4:18 PM	Kelley
Incident:	Fire Alarm		
Location:	Smith Hall		
Details:	Detector activated from unknown cause		
120-08	01/17/08	7:40 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. E		
Details:	Resident blow-drying hair activated detector		
121-08	01/18/08	8:23 AM	Stevenson
Incident:	Fire Alarm		
Location:	Live Animal Research Bldg. 64		
Details:	Steam in air handling units activated alarm		
122-08	01/17/08	11:02 PM	Kelley
Incident:	Fire Alarm		
Location:	Classroom Bldg. 1 st floor, NW exit		
Details:	Unknown person pulled pull box		