

OSU EHS Department
Incident Summary
For the Period 01/28/08 – 02/03/08

128-08	01/29/08	4:15 AM	Nutt
Incident:	Fire Alarm		
Location:	Carreker Hall West		
Details:	Alarm activated by a sprinkler flow switch		

129-08	01/29/08	3:20 PM	Nutt
Incident:	Fire Alarm		
Location:	Gallagher Iba Arena		
Details:	Pull box activated—no fire		

130-08	02/01/08	9:08 AM	Stevenson
Incident:	Fire Alarm		
Location:	Young Hall		
Details:	Alarm activated by smoke from hot grease that spilled on stove		

131-08	02/01/08	9:05 AM	Nutt
Incident:	Ambulance Assist		
Location:	North University Apartments		
Details:	Patient having difficulty breathing		
