

**OSU EHS Department
Incident Summary**
For the Period 03/24/08 – 03/30/08

179-08	03/26/08	8:30 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		
180-08	03/26/08	11:16 AM	Germain
Incident:	Fire Alarm		
Location:	Bennett Hall		
Details:	Steam from shower activated smoke detector		
181-08	03/26/08	7:20 PM	Kelley
Incident:	Fire Alarm		
Location:	Cordell Hall, center wing, 1 st floor, SW exit		
Details:	Alarm pull box accidentally pulled		
182-08	03/24/08	11:32 AM	Spybuck
Incident:	Chemical Spill		
Location:	Booker Hall, South end, outside by dumpster, parking lot 75A		
Details:	Unknown spilled substance		
183-08	03/27/08	3:07 PM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Steam from shower activated smoke detector		
184-08	03/29/08	9:07 AM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartments, Bldg. B		
Details:	Heat from hair dryer activated smoke detector		
185-08	03/29/08	5:29 PM	Kelley
Incident:	Fire Alarm		
Location:	Bennett Hall West		
Details:	Candle and container melted onto TV cabinet		
186-08	03/30/08	5:37 PM	Kelley
Incident:	Fire Alarm		
Location:	Village Apartment,s Bldg. E		
Details:	Unattended candle melted and activated smoke detector		
188-08	03/27/08	3:50 PM	Nutt
Incident:	Fire		
Location:	Kamm parking lot, south		
Details:	Car on fire		