

**OSU EHS Department
Incident Summary**
For the Period 05/05/08 – 05/11/08

221-08	05/05/08	2:04 PM	Nutt
Incident:	Ambulance Assist		
Location:	Morrison Apartments		
Details:	Unknown medical emergency		
222-08	05/07/08	12:25 PM	Nutt
Incident:	Fire Alarm		
Location:	Smith Apartments		
Details:	Burned food activated smoke detector		
224-08	05/07/08	5:57 PM	Kelley
Incident:	Fire Alarm		
Location:	Young Hall		
Details:	Smoke from cooking activated detector		
225-08	05/08/08	7:26 AM	Nutt
Incident:	Fire Alarm		
Location:	Classroom Bldg.		
Details:	Dust from carpenter's sanding activated detector		
226-08	05/08/08	1:55 PM	Nutt
Incident:	Ambulance Assist		
Location:	Outside of North Murray		
Details:	Patient tripped on steps		
227-08	05/09/08	10:17 AM	Stevenson
Incident:	Fire Alarm		
Location:	Village Apartments		
Details:	Pull box activation—no fire		
228-08	05/09/08	7:10 AM	Nutt
Incident:	Fire Alarm		
Location:	Village Apartments		
Details:	Pull box activation—no fire		
229-08	05/10/08	3:00 PM	Kelley
Incident:	Ambulance Assist		
Location:	Baseball Stadium		
Details:	Spectator hit in face by baseball		
230-08	05/10/08	3:04 PM	Kelley
Incident:	Fire Alarm		
Location:	CITD Bldg.		
Details:	Unknown cause		
231-08	05/10/08	6:36 PM	Kelley
Incident:	Fire Alarm		
Location:	Bennett Hall East		
Details:	Dust in detector activated smoke detector		